



# Havelock Wastewater Treatment Plant (WWTP) Schedule 'C' Municipal Class Environmental Assessment

Public Information Centre No. 2



# Why Are We Here?

- The Township of Havelock-Belmont-Methuen and the Ontario Clean Water Agency (OCWA) are undertaking a **Municipal Class Environmental Assessment Study** to complete infrastructure upgrades at the Havelock Wastewater Treatment Plant (WWTP)
- The objectives of this **Public Information Centre** are to:



Provide an update on the project progress



Present the evaluation of design concepts and preferred solutions



Provide an opportunity for the public to get involved in the project

# We Need Your Input!

Your feedback  
is important to  
this Class  
Environmental  
Assessment  
Study!



Please review the PIC presentation to learn about the process, the activities completed to date, and the **Preferred Solution** being recommended.



**Your opinion is important to us!**  
Members of the project team are available to answer questions via email or telephone.



Please complete the **Online Comment Form** after reviewing the materials.

# What is the Purpose of the Study?



- To plan for additional wastewater servicing capacity to support growth in the Village to 2041.
- To identify improvements required at the Havelock Wastewater Treatment Plant to increase its capacity, while minimizing impacts on the natural and socio-cultural environments and reducing its life cycle cost

# Schedule 'C' Municipal Class EA Process and Timeline



## Getting Started


- Review available information/data
- Identify **Problem / Opportunity Statement**

NOTICE OF COMMENCEMENT

August 2021

# Proposed Growth and Design Flows for the Havelock WWTP

- Planned growth in the Havelock South Development Area
  - 3 phases of residential homes
  - Peterborough Housing Development
  - Havelock Long-Term Care (LTC) Facility
- Additional anticipated growth to 2,400 people in the study area over a 20-year planning period to 2041



# Schedule 'C' Municipal Class EA Process and Timeline

## Getting Started

- Review available information/data
- Identify **Problem / Opportunity Statement**

NOTICE OF COMMENCEMENT

August 2021

## Exploring the Options

- Consider ways to address existing concerns
- Identify potential impacts
- Evaluate options and select the **Preliminary Preferred Solution**

VIRTUAL PUBLIC INFORMATION CENTRE #1

March 2022


# Review of PIC No.1

## List of Alternative Solutions – Screening Results

#	Alternative Solutions	Screening and Recommendation
1.	Do Nothing	<b>Eliminated</b> – alternative would lead to non-compliance and plant by-passes with an increased risk of wastewater system failure.
2.	Limit Community Growth	<b>Eliminated</b> – alternative would not allow for any additional future development beyond the capacity of the WWTP leading to non-compliance with growth objectives.
3.	Reduce Inflow and Infiltration (I/I)	<b>Eliminated</b> – I/I Control measures already in place. Not recommended as a stand-alone solution. Could be included as part of a preferred solution.
4.	Expand the Existing Havelock WWTP	<b>CARRIED FORWARD</b>
5.	Construct a New WWTP on the Existing Site	<b>Eliminated</b> – alternative addresses the need for additional wastewater servicing capacity, but it does not maximize use of existing infrastructure.
6.	Construct a New WWTP on a New Site	<b>Eliminated</b> – alternative addresses the need for additional wastewater servicing capacity, but it does not maximize use of existing infrastructure.




# Schedule 'C' Municipal Class EA Process and Timeline



# Overview of Existing Havelock Wastewater Treatment Plant (WWTP)


- **Location:**  
719 Old Norwood Road
- **Rated Capacity:**  
1,200 m<sup>3</sup>/d
- **Year of Construction:**  
2009



# Key Process Components of the Havelock WWTP

## Plant Processes

- Raw Sewage Pumping Station
- Septage and Hauled Waste Receiving Facility
- Headworks
- Sequencing Batch Reactor (SBR) Treatment Tanks
- Equalization Tank
- Up-flow Sand Filters
- Chemical Addition for phosphorus removal
- UV Disinfection
- Sludge Treatment
- Outfall pipe to Plato Creek
- Existing lagoons – abandoned




# Existing Lagoons Havelock WWTP




# Overview of Wastewater Treatment Process

## Process Flowchart




# Overview of Wastewater Treatment Process

Use existing technology  
at the plant



# Overview of Wastewater Treatment Process



# Secondary Treatment Technology Review


## Secondary Treatment

- Conventional Activated Sludge (CAS)
- Ballasted Activated Sludge
- Biological Phosphorus Removal – Using CAS
- Membrane Bioreactor
- Membrane Aerated Biofilm Reactor (MABR)
- Integrated Fixed-Film Activated Sludge / Moving Bed Bioreactor
- **Sequencing Batch Reactor (SBR)** ★
- Aerobic Granular Sludge
- Biological Aerated Filter





# Overview of Wastewater Treatment Process



# Filtration Design Criteria


- Assimilative Capacity Study completed
  - Plato Creek sensitive to phosphorus in the effluent during low flow conditions
- Two WWTP discharge scenarios were considered:
  - **Continuous discharge** – requires very strict effluent objectives for total phosphorus
  - **Seasonal effluent equalization/storage** – requires less stringent effluent objectives for total phosphorus




# Filtration Technology Review

## Filtration

- **Deep Bed Filter** ★
- Disc Filter
- Membrane Bioreactor (MBR)
- Membrane Filtration
- **Two-stage Filtration** ★



# Overview of Wastewater Treatment Process




# Disinfection Technology Review

## Disinfection


- **Ultraviolet (UV) Disinfection**
- Ozone
- Peracetic Acid (PAA)



# Overview of Wastewater Treatment Process




# Overview of Wastewater Treatment Process



# Design Concept 1

## Expand Mechanical Plant Without use of Lagoons




- **Preliminary Treatment**
  - Increase raw sewage pump capacity
  - Increase screening capacity



# Design Concept 1

## Expand Mechanical Plant Without use of Lagoons




- **Secondary Treatment**

- Increase capacity by adding new SBR tank

# Design Concept 1

## Expand Mechanical Plant without use of Lagoons




### •Filtration

- Increase capacity of existing filtration system
- Add second filtration stage to meet low phosphorus requirements

# Design Concept 1

## Expand Mechanical Plant Without use of Lagoons




- **Disinfection:**

- Increase capacity of existing UV system

# Design Concept 1

## Expand Mechanical Plant Without use of Lagoons




- **Biosolids:**

- Additional aerobic digester
- Additional biosolids storage tank


# Design Concept 1

## Expand Mechanical Plant Without use of Lagoons



# Design Concept 2


## Use Existing Lagoon for Influent Equalization



- **Lagoon Modifications**
  - Drain/clean/repair decommissioned lagoons
  - New pump station

# Design Concept 2


## Use Existing Lagoon for Influent Equalization



- **Secondary Treatment**
  - Additional SBR train

# Design Concept 2

## Use Existing Lagoon for Influent Equalization




- **Tertiary Filtration**
  - Install dual stage filtration



# Design Concept 2

## Use Existing Lagoon for Influent Equalization




### •Biosolids:

- Additional aerobic digester
- Additional biosolids storage tank


# Design Concept 2

## Expand Mechanical Plant Using Lagoon for Influent Equalization



# Design Concept 3


## Use Existing Lagoons for Secondary Effluent Storage



- **Preliminary Treatment**
  - Increase raw sewage pump capacity
  - Increase screening capacity

# Design Concept 3


## Use Existing Lagoons for Secondary Effluent Storage



- **Secondary Treatment**
  - Additional SBR train

# Design Concept 3


## Use Existing Lagoons for Secondary Effluent Storage



- **Tertiary Filtration**
  - Increase filtration capacity

# Design Concept 3


## Use Existing Lagoons for Secondary Effluent Storage



- **Disinfection**
  - Increase UV disinfection capacity

# Design Concept 3

## Use Existing Lagoons for Secondary Effluent Storage




- **Lagoon Modifications**

- Drain/clean/repair decommissioned lagoons
- New pump station

# Design Concept 3

## Use Existing Lagoons for Secondary Effluent Storage




### •Biosolids:

- Additional aerobic digester
- Additional biosolids storage tank




# Design Concept 3

## Use Existing Lagoons for Secondary Effluent Storage



# Design Concept 4

## Use Existing Lagoons for Filtered Effluent Storage




- **Preliminary Treatment**

- Increase raw sewage pump capacity
- Increase screening capacity

# Design Concept 4


## Use Existing Lagoons for Filtered Effluent Storage



- **Secondary Treatment**
  - Additional SBR train

# Design Concept 4


## Use Existing Lagoons for Filtered Effluent Storage



- **Tertiary Filtration**
  - Increase filtration capacity

# Design Concept 4


## Use Existing Lagoons for Filtered Effluent Storage



- **Disinfection**
  - Increase UV disinfection capacity


# Design Concept 4

## Use Existing Lagoons for Filtered Effluent Storage



# Design Concept 4

## Use Existing Lagoons for Filtered Effluent Storage




### •Biosolids:

- Additional aerobic digester
- Additional biosolids storage tank

# Design Concept 4


## Use Existing Lagoons for Filtered Effluent Storage





# Detailed Evaluation Criteria


- Public and Operator Health and Safety
- Aesthetic and Operational Impacts
- Construction Impacts
- Archaeological/ Cultural Heritage Features
- Life-cycle Capital and O&M Cost



- Effluent Receiving Water Body Assessment
- Sensitive Natural Features and Regulated Areas
- Climate Change
- Operational Complexity
- Ease of Implementation
- Redundancy and Flexibility
- Energy efficiency
- Constructability
- Regulatory Approvals

# Preliminary Evaluation of Design Concepts

Evaluation Criteria	Design Concept 1	Design Concept 2	Design Concept 3	Design Concept 4
<b>Socio-Cultural Criteria</b>				
Public and Operator Health and Safety	●	●	●	●
Aesthetic and Operational Impacts	●	◐	◐	◑
Archaeological/ Cultural Heritage Features	●	●	●	●
Construction Impacts	●	●	◑	◑
<b>Natural Environmental Criteria</b>				
Effluent Receiving Water Body Assessment	●	◑	◑	◐
Sensitive Features and Regulated Areas	●	◐	◐	◐
Climate Change	◐	●	●	◑
<b>Technical Considerations</b>				
Operational Complexity	◑	●	◐	◑
Ease of Implementation	◑	●	◐	◑
Redundancy and Flexibility	◐	●	◑	◑
Energy Efficiency	◑	●	◐	◐
Constructability	◐	●	◐	◐
<b>Economic Considerations</b>				
Capital	◑	●	◐	◐
O&M Cost	●	◐	◑	◐



## Design Concept 2

### Use Existing Lagoon for Influent Equalization

- Rehabilitated equalization lagoon
- New lagoon return pump station
- New third SBR train
- New dual staged filters
- No expansion of preliminary treatment and disinfection system required
- Expand biosolids storage
- Other Upgrades (Civil, Mechanical, Electrical, etc.)
- Capital cost **\$14 Million**



# What are the Next Steps?

---

- Determine staging and phasing of upgrade and expansion
- Prepare the Environmental Study Report documenting project information and the decision-making process
- Environmental Study Report available for ***30-day review period for public and agency comment.***

# Thank you for Participating! Please Stay Engaged

Please provide your comments by  
November 22, 2022.

Should you have any questions about this  
presentation or the project, please contact:



---

Amber Coupland  
OCWA  
Project Manager  
[acoupland@ocwa.com](mailto:acoupland@ocwa.com)



---

Mina Yousif, M.Eng., P.Eng., PMP  
CIMA+  
Project Manager  
[Mina.Yousif@cima.ca](mailto:Mina.Yousif@cima.ca)